



**ADDENDUM #1
Public Works
Sugarloaf Retaining Walls at SH-119
BID # 7232-21**

May 18, 2021

The attached addendum supersedes the original Information and Specifications regarding BID # 7232-21 where it adds to, deletes from, clarifies or otherwise modifies. All other conditions and any previous addendums shall remain unchanged.

Please note: Due to COVID-19, BIDS will only be accepted electronically by emailing purchasing@bouldercounty.org.

Additional documents included in this addendum:

- Pre-Bid Meeting Agenda.
- Pre-Bid Meeting Sign-In Sheet.
- Revision of Section 107 - Responsibility of Damage Claims, Insurance Types and Coverage.
- Updated Bid Tab (attached separately).

1. Question: What is the engineer's estimate?

ANSWER: We cannot share the Engineering estimate.

2. Question: Does the designer anticipate temporary shoring?

ANSWER: Temporary shoring is not anticipated.

3. Question: Does a bid bond need to be submitted?

ANSWER: Yes, See Sheet A-4 for bid bond requirements.

4. Question: Please provide the Bid Tab in Excel format.

ANSWER: Excel format is included in Addendum 1.

5. Question: Can the PIM be added to the bid tab as its own pay item?

ANSWER: The PIM as described in Section 626 will be included in the overall bid and is not a single line item.

6. Question: Will you provide allowance for F/A Minor Contract revisions and erosion control?

ANSWER: F/A MCR and F/A erosion control are already in the bid tab already.

Submittal Instructions:

Submittals are due at the email box only, listed below, for time and date recording on or before **10:00 a.m. Mountain Time on May 28, 2021.**

Please note that email responses to this solicitation are limited to a maximum of 50MB capacity.

NO ZIP FILES OR LINKS TO EXTERNAL SITES WILL BE ACCEPTED. THIS INCLUDES GOOGLE DOCS AND SIMILAR SITES. ALL SUBMITTALS MUST BE RECEIVED AS AN ATTACHMENT (E.G. PDF, WORD, EXCEL).

Electronic submittals must be received in the email box listed below. Submittals sent to any other box will NOT be forwarded or accepted. This email box is only accessed on the due date of your questions or proposals. Please use the Delivery Receipt option to verify receipt of your email. It is the sole responsibility of the proposer to ensure their documents are received before the deadline specified above. Boulder County does not accept responsibility under any circumstance for delayed or failed email or mailed submittals.

Email purchasing@bouldercounty.org; identified as **BID # 7232-21** in the subject line.

All proposals must be received and time and date recorded at the purchasing email by the above due date and time. Sole responsibility rests with the Offeror to see that their bid is received on time at the stated location(s). Any bid received after due date and time will be returned to the bidder. No exceptions will be made.

The Board of County Commissioners reserve the right to reject any and all bids, to waive any informalities or irregularities therein, and to accept the bid that, in the opinion of the Board, is in the best interest of the Board and of the County of Boulder, State of Colorado.



**RECEIPT OF LETTER
ACKNOWLEDGMENT**

May 18, 2021

Dear Vendor:

This is an acknowledgment of receipt of Addendum #1 for BID #7232-21, Sugarloaf Retaining Walls at SH-119.

In an effort to keep you informed, we would appreciate your acknowledgment of receipt of the preceding addendum. Please sign this acknowledgment and email it back to purchasing@bouldercounty.org as soon as possible. If you have any questions, or problems with transmittal, please call us at 303-441-3525. This is also an acknowledgement that the vendor understands that **due to COVID-19, BIDS will only be accepted electronically by emailing purchasing@bouldercounty.org.**

Thank you for your cooperation in this matter. This information is time and date sensitive; an immediate response is requested.

Sincerely,

Boulder County Purchasing

Signed by: _____ **Date:** _____

Name of Company _____

**NON – Mandatory PRE-BID MEETING AGENDA
Boulder County Public Works – Engineering Division**

Date: May 10, 2021 Time: 11:00 A.M. Project No. RD-122-000, F0-S48

Location: [Microsoft Teams Meeting](#)
+1 720-400-7859 United States, Denver (Toll), Conference ID: 545 293 91#

Description: **Sugarloaf Road Retaining Walls at SH 119**

Boulder County Project RD-122-000
Bid #7232-21

1. INTRODUCTIONS, SIGN-UP SHEET

1. Owners:
 - a. Boulder County

2. GENERAL DESCRIPTION

1. This project includes the full depth asphalt replacement and widening of Sugarloaf Road, construction of culverts, gravity block wall, natural stone wall facing, excavation (including rock excavation), guardrail replacement, and associated signing and striping.

3. BID SCHEDULE

1. BID Questions Due: 2:00 PM, Monday, May 17, 2021
2. Question Response by end of day Friday, May 21, 2021
3. Submittal Due Date: 10:00 AM, Friday, May 28, 2021
4. Submit to Email Address: purchasing@bouldercounty.org

4. SUBMITTAL PACKAGE

1. Completed Bid Tabulation
2. Insurance Certificate
3. W-9
4. Signature Page
5. Addendum Acknowledgement(s)

5. AVAILABLE BID DOCUMENTS

Drop Box: <https://www.dropbox.com/sh/adu0ife3zom8sc0/AAA2IBBB6WXE101XaR6qfrEka?dl=0>

1. Includes:
 - a. Sugarloaf~170127~GeotechExtractedfromWallSelectionMemo.pdf
 - b. Sugarloaf~FloodplainPermitSigned~210302~FDP-21-007.pdf
 - c. SugarloafRd~Bid~21.04.26~Plans.pdf
2. Specifications are located in the Bid Document itself

6. GENERAL REQUIREMENTS

1. Permits responsibility of Contractor (included, but not limited to)
 - a. State CDPHE
 - b. Boulder County SWQP

7. UTILITIES

1. Xcel:
 - a. Overhead Electric:
2. Century Link (Fiber Optic)
3. Comcast (Cable Communications)
4. Sugarloaf Fire Protection District Station 2
5. City of Boulder Department of Public Works
6. BETASSO WTP Improvement Project

All anticipated relocations are completed

8. RIGHT OF WAY

1. Anticipate full rights to right-of-way before start of construction.

9. CONSTRUCTION PLANS AND REQUIREMENTS

1. Performed in compliance with 2019 CDOT specification, and Boulder County Multimodal Transportation Standards. The most restrictive specification shall govern.
2. 100 Construction days plus 10 days for punch list, winter suspension is excluded if no work is performed. Roadway must be maintained during non-work periods.
3. Material QC testing by the contractor. QA and acceptance testing by the County.
4. The contractor shall designate a Public Information Manager (PIM). Please refer to the specifications. Public Information Services will not be measured and paid for separately but be included with the items in under Section 630 Construction Zone Traffic Control.
5. Rock excavation is expected to be ample for this project. No blasting for rock excavation will be allowed. All rock excavation shall be via mechanical means and methods.
6. Property Owner Concerns
Coordination with the owner at 75 Sugarloaf Road will be required. Refer to the Removal and Reset Plans for additional information.

10. ADDENDUM

1. Forthcoming
 - a. Submittal Section (Page 116, PDF Page 114)
 - i. The following items are NOT required to submit
 - 1) Name and Address of the Partners and Subcontractors if applicable
 - 2) A detailed project schedule with an all-inclusive total cost
 - 3) Information on the relevant experience of key personnel
 - 4) State your compliance with the Terms and Conditions in the Sample Contract contained in this BID. Specifically list any deviations and provide justification for each deviation.
 - 5) Submit three references for similar projects your company has completed within the last three years and contact information
 - ii. The following items ARE required to submit
 - 1) Completed Bid Tabulation
 - 2) Insurance Certificate
 - 3) W-9
 - 4) Signature Page
 - 5) Addendum Acknowledgement(s) (If Applicable)
 - b. Fire Insurance required for CDOT Permitting
 - i. Commercial General Liability Insurance written on ISO occurrence form CG 00 01 10/93 or equivalent, covering premises operations, fire damage, independent Consultants, products and completed operations, blanket contractual liability, personal injury and advertising liability with minimum limits as follows:
 - 1) \$1,000,000 Each Occurrence,
 - 2) \$2,000,000 General Aggregate and
 - 3) \$2,000,000 Products/Completed Operations Aggregate.
 - 4) \$50,000 Fire Insurance

11. QUESTIONS

1. What is the engineer's estimate?
 - a. We cannot share the Engineering estimate.

2. Does the designer anticipate temporary shoring?
 - a. Temporary shoring is not anticipated.

3. Does a bid bond need to be submitted?
 - a. Yes, See Sheet A-4 for bid bond requirements.

4. Please provide the Bid Tab in Excel format.
 - a. Excel format is included in Addendum 1.

5. Can the PIM be added to the bid tab as its own pay item?
 - a. The PIM as described in Section 626 will be included in the overall bid and is not a single line item.

6. Will you provide allowance for F/A Minor Contract revisions and erosion control?
 - a. F/A MCR and F/A erosion control are already in the bid tab already.



BOULDER COUNTY PUBLIC WORKS MEETING SIGN-IN SHEET

MEETING TYPE: FIR FOR GENERAL PRE-BID PRE-CONSTRUCTION

Project Title: Sugarloaf Road Retaining Walls at SH 119		Project No. RD-122-000, Bid #7232-21	
Federal Project? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Federal Project No.	Federal Code	
Date, Time: May 10, 2021, 11:00 AM		Location: MS Teams	

[MEETING TYPE] SIGN-IN SHEET		PROJECT:	
NAME/SIGNATURE	COMPANY	PHONE NUMBER	EMAIL ADDRESS
Jude Klob	American West	305-395-9264	jkolb@trustawc.com
Cameron Mang	SEMA	303-627-2600	Estimating.co@semaconstruction.com
Scott Davis	Rock & Company	303-210-1523 (cell)	scott@rockandco.com
Matt Reese	American Civil Constructors	303-738-5103	Matt.reese@accbuilt.com
Peter Saint	Siete, Inc.	719-676-7777	bids@sieteinc.net
Carl Henderson	Ground Engineering Consultants, Inc.	303-289-1989	Carl.henderson@groundeng.com
Scott Palmer	EDGE Contracting	303-519-0050	spalmer@edgecontracting.com
Naresh Surigala	JHL Constructors	303-741-6116	nsurigala@jhlconstructors.com

[MEETING TYPE] SIGN-IN SHEET		PROJECT:	
NAME/SIGNATURE	COMPANY	PHONE NUMBER	EMAIL ADDRESS
Todd Gunderman	JUB	801-641-8951	tgunderman@jub.com
Sean Weddingfeld	Myers & Sons Construction	303-775-3238	sweddingfeld@myers-sons.com
Kevin Dooley	Otak	720-758-7721	Kevin.dooley@otak.com
Elliot Van Stelle	Structures, Inc.	303-770-7878	elliott@structuresinc.net
Eric Petrie	SEMA	303-921-6011	Estimating.co@semaconstruction.com

**REVISION OF SECTION 107
RESPONSIBILITY OF DAMAGE CLAIMS, INSURANCE TYPES AND COVERAGE**

Subsection 107.15 shall be revised to include the following:

All insurance policies in this section shall name Boulder County and the Colorado Department of Transportation as additional insured.

THE ADDITIONAL INSURED WORDING SHOULD BE AS FOLLOWS: County of Boulder, State of Colorado, a body corporate and politic, and Colorado Department of Transportation and Concessionaire are named as Additional Insureds **including completed operations**.

Subsection 107.15 (a) insurance kinds and amounts shall be replaced (when applicable) as follows:

Commercial General Liability

Coverage should be provided on an Occurrence form, ISO CG0001 or equivalent. The policy shall be endorsed to include Additional Insured Owners, Lessees or Contractors endorsements CG 2038 (or equivalent), Designated Construction Project(s) General Aggregate Endorsement CG2503 (or equivalent) and Additional Insured Completed Operations for Owners, Lessees or Contractors CG 2037 (or equivalent). Minimum limits required of:

- \$1,000,000 Each Occurrence,
- \$2,000,000 General Aggregate and
- \$2,000,000 Products/Completed Operations Aggregate; and
- \$50,000 any one fire.

The County requires the Products/Completed Operations coverage to be provided 3 years after completion of construction. An endorsement must be included with the certificate.

Automobile Liability

Bodily Injury and Property Damage for any owned, hired, and non-owned vehicles used in the performance of the Contract. Minimum limits \$1,000,000 Each Accident.

Worker's Compensation and Employer's Liability

Workers' Compensation must be maintained with the statutory limits. Employer's Liability is required for minimum limits of \$100,000 Each Accident/\$500,000 Disease-Policy Limit/\$100,000 Disease-Each Employee.

Umbrella / Excess Insurance

Umbrella/Excess Liability insurance in the amount \$3,000,000.00, following form.