

Boulder County LID – Eldorado Springs Wastewater Plant
Operations Report
April 2021

Prepared by Gabby Begeman, ORC Water Professionals

WWTP

- Please see the attached results for the samples and flows collected from the WWTF.
- We are experiencing an upset condition with the facility that has resulted in a lack of nitrification. All parameters are normal, DO is adequate, valves are working, there is no leakage or other bypass occurring. We have begun to add bugs to the system in hopes of jump starting the process again. We have submitted an effluent sample to the lab for pesticides in an attempt to find a root cause for the upset.

Collections system

- No grinders required replacement/repair in April.

