



ADDENDUM #1
Public Works
Minor Structure Replacement of Riverside Drive Over Cave Creek
BID # 7496-23

August 24, 2023

The attached addendum supersedes the original Information and Specifications regarding BID # 7496-23 where it adds to, deletes from, clarifies or otherwise modifies. All other conditions and any previous addendums shall remain unchanged.

Please see the agenda and sign in sheet from the Optional Pre-Bid Meeting held on August 15, 2023 at the end of this document.

Please note: BIDS will only be accepted electronically by emailing purchasing@bouldercounty.gov.

1. Question: With regards to the Structure repair work on Riverside Drive over Cave Creek. Please note the 14'x7' Precast Concrete Box Culvert is not a typical size and therefore cannot be precast. The Size would need to be adjusted to 14'x8'. Also, per the construction time frame of 120 working days would not be sufficient to get a precast box culvert if the size was changed, due to the delay with the schedules of the precast vendors.

Would a cast in place box culvert be considered? Once again the construction timeframe would need to be extended to allow for the additional on-site work to cast in place vs. the pre-cast box culvert.

ANSWER: Caste in place is not acceptable. Build box as designed and county is amenable to update working days to accommodate precast schedule.

2. Question: Is it acceptable to precast the "Bridge Rail (Special)" in sections in lieu of pour-in-place?

ANSWER: No.

3. Question: Will CAD files be available for the bidders?

ANSWER: CAD files will be available for the selected contractor.

4. What permits will Boulder County Provide?

ANSWER: The Army Corps 404 and Boulder County Flood Plain Permit will be provided by Boulder County.

5. Is there a preferred vendor for the pre-cast box culvert?

ANSWER: No vendor has been pre-selected.

Submittal Instructions:

Submittals are due at the email box only, listed below, for time and date recording on or before **2:00 p.m. Mountain Time on August 29, 2023.**

Please note that email responses to this solicitation are limited to a maximum of 50MB capacity.

NO ZIP FILES OR LINKS TO EXTERNAL SITES WILL BE ACCEPTED. THIS INCLUDES GOOGLE DOCS AND SIMILAR SITES. ALL SUBMITTALS MUST BE RECEIVED AS AN ATTACHMENT (E.G. PDF, WORD, EXCEL).

Electronic submittals must be received in the email box listed below. Submittals sent to any other box will NOT be forwarded or accepted. This email box is only accessed on the due date of your questions or proposals. Please use the Delivery Receipt option to verify receipt of your email. It is the sole responsibility of the proposer to ensure their documents are received before the deadline specified above. Boulder County does not accept responsibility under any circumstance for delayed or failed email or mailed submittals.

Email purchasing@bouldercounty.gov; identified as **BID # 7496-23** in the subject line.

All proposals must be received and time and date recorded at the purchasing email by the above due date and time. Sole responsibility rests with the Offeror to see that their bid is received on time at the stated location(s). Any bid received after due date and time will be returned to the bidder. No exceptions will be made.

The Board of County Commissioners reserve the right to reject any and all bids, to waive any informalities or irregularities therein, and to accept the bid that, in the opinion of the Board, is in the best interest of the Board and of the County of Boulder, State of Colorado.



**RECEIPT OF LETTER
ACKNOWLEDGMENT**

August 24, 2023

Dear Vendor:

This is an acknowledgment of receipt of Addendum #1 for BID #7496-23, Minor Structure Replacement of Riverside Drive Over Cave Creek.

In an effort to keep you informed, we would appreciate your acknowledgment of receipt of the preceding addendum. Please sign this acknowledgment and email it back to purchasing@bouldercounty.gov as soon as possible. If you have any questions, or problems with transmittal, please call us at 303-441-3525.

This is also an acknowledgement that the vendor understands that **BIDS will only be accepted electronically by emailing purchasing@bouldercounty.gov.**

Thank you for your cooperation in this matter. This information is time and date sensitive; an immediate response is requested.

Sincerely,

Boulder County Purchasing

Signed by: _____ **Date:** _____

Name of Company _____



BOULDER COUNTY PUBLIC WORKS PRE-BID MEETING AGENDA

Date: 8/15/2020 Time: 10:00 AM County Proj. No.: BC-103-009

Location: Riverside Federal Proj. No.: N/A Code: N/A

THIS PROJECT CONSISTS OF REPLACING AN EXISTING CAST-IN-PLACE CONCRETE SLAB ON STONE MASONRY ABUTMENTS AND WINGWALLS WITH A 14'Wx7'H (INTERIOR DIMENSIONS) CONCRETE BOX CUL VERT WITH CAST-IN-PLACE CONCRETE HEADWALLS, CAST-IN-PLACE DOGHOUSE RAIL, WINGWALLS, AND TOEWALLS.

THE PROJECT ALSO INCLUDES CLEARING AND GRUBBING, REMOVALS (ASPHALT, STRUCTURES, SIGNS), EXCAVATION AND BACKFILL, SEEDING, MULCHING, EROSION CONTROL, DEWATERING, ASPHALT PAVING, RIPRAP, GUARDRAIL, TRAFFIC CONTROL WITH A ROAD CLOSURE AND DETOUR, CONSTRUCTION SURVEYING, STRIPING, AND MOBILIZATION.

Description: _____

I. INTRODUCTIONS:

- a. Boulder County Project Team
 - i. Colton Coughlin – Project Manager and Engineer
 - ii. Andrew Barth – Public Information Officer
- b. S.E.H.
 - i. Steve Kaye – Design Project Manager & Engineer
- c. CM&I Team
 - i. Bill Eliassen
- d. Sign-in Sheet provided: All bidders to provide contact information.
 - i. Sheet will be provided to all contractors following the meeting.

II. PROJECT OVERVIEW:

- e. Project Description and General Site overview:
 - i. Project Schedule –120 working days
 - ii. Maintain driveway/roadway access points.
 - iii. Traffic Control
 1. Road closure with off-site detour on SH72 and SH 7
 - iv. Temporary shoring for structure excavation, coordinate with fiber line utility support/protection.
 - v. Coordinating with utilities
 1. Existing Lumen fiber optic line must be temporarily supported and protected during existing bridge demolition and new structure installation.
 - vi. "Doghouse" rail item includes transition pieces.
 - vii. Temporary Diversion Options
 - viii. Property owner items shown on Sheet No. 11
 - ix. Working Hours
 1. 8am to 4:30 pm
 - x. BOCO SWMP Permit <https://www.bouldercounty.org/transportation/permits/stormwater-quality-permit/>
- f. Specification Overview

III. BID DOCUMENTS AND CHANGES TO DOCUMENTS:

- g. Obtaining Plans and Specifications:
- h. <https://www.dropbox.com/scl/fo/7rzsxy9tvl3vbrd1iv1vh/h?rlkey=ioa56z0qwlokprkods3gtrbvb&dl=0>
- i. All inquiries regarding this BID will be submitted via email to the Boulder County Purchasing Office at purchasing@bouldercounty.gov on or before 2:00 p.m. **August 21th, 2023**. A response from the county to all inquiries will be posted and sent via email no later than **August 24th, 2023**.
 - a. Drawing and Specification changes will be posted to the website and notice will be sent via Addendum.

IV. SCHEDULE OF EVENTS:

- b. Publication: 7/31/2023
- c. Question Acceptance Deadline: 2:00 PM 8/21/2023
- d. Question Answer Deadline: 8/24/2023 EOB

BOULDER COUNTY TRANSPORTATION FIR/FOR MEETING AGENDA

- e. Closing Date: 2:00 PM 8/29/2023
- f. Contract Award Date: (TBD)

V. OPEN QUESTION AND COMMENT:



PUBLIC WORKS - ENGINEERING MEETING SIGN-IN SHEET

MEETING TYPE: FIR FOR GENERAL PRE-BID PRE-CONSTRUCTION

Project Title: Minor Structure Replacement of Riverside Drive Over Cave Creek		Project No. BC-103-009
Federal Project? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Federal Project No. N/A	Federal Code N/A
Date, Time: August 15 th at 10:00am		Location: MS Teams

[MEETING TYPE] SIGN-IN SHEET		PROJECT:	
NAME/SIGNATURE	COMPANY	PHONE NUMBER	EMAIL ADDRESS
Colton Coughlin	Boulder County	303.682.6779	ccoughlin@bouldercounty.gov
Bill Eliassen	Boulder County	303.489.4167	beliasen@bouldercounty.gov
Steve Kaye	S.E.H.	720.540.6847	skaye@sehinc.com
Jeff Davis	Boulder County	303.441.1125	jdavis@bouldercounty.gov
Ronald Gibbens	Dietzler CO.	720.597.0338	rgibbens@dietzlerco.com
Jerry Roberts	Stone & Concrete	303.949.3037	Jerry@DirectDenver.com
Amber Saffer	Mountain Constructors	970-456-2765	bids@mtnconstructors.com
Liz Holden	Hallmark	303.423.8005	office@hallmark-inc.com

[MEETING TYPE] SIGN-IN SHEET		PROJECT:	
NAME/SIGNATURE	COMPANY	PHONE NUMBER	EMAIL ADDRESS
Tim Lee	Coal Creek Excavation	303.859.9513	tim@coalcreekexcavation.com
Bill Sisko	Coal Creek Excavation	303.859.9513	bill@coalcreekexcavation.com
Jon Miklya	American West Construction, LLC	303.918.1667	jmiklya@trustawc.com
Dan Jessop	TWX	970.294.5804	dan@twolfx.com
John Waechter	Geocraftbuilders	719.204.9269	john@geocraftbuilders.com
Doug Tirpak	Boulder County	720.564.2654	dtirpak@bouldercounty.gov